HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY: Indell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Donnie Walker OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 4-12-94
PROPOSED FACILITY: 3 Bedroom SW MH
PROPERTY SIZE:
LOCATION OF SITE: Mt. Rd. Village Lot # 15
WATER SUPPLY: On-Site Well Comm. Well Public ✓ Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	4-6% L	0-8"	l	gr	1:1 / vfr	.1942 WETNES CONDITION	P.S.
		8"-48"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
2	3-5% L	0-7"	l	gr	1:1 / vfr	.1942 WETNES CONDITION	P.S.
		7"-36"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	36"-↑ c/sap mix
		36"-↑	c/sap mix			.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
3	3-5% L	0-5"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION	P.S.
		5"-37"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	37"-↑ c/sap mix
		37"-↑	c/sap mix			.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35.
4	2-4% L	0-9"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION	P.S.
		9"-48"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) P.S. SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1946): SYSTEM TYPE conventional, gravity fed.
EVALUATED BY: Michael & Donnie OTHER(S) PRESENT:
COMMENTS:

DRAFT