HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Conley Warren OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 5-30-95
PROPOSED FACILITY:
PROPERTY SIZE: 2 acres
LOCATION OF SITE:
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN.)	1941 (a)(1) TEXTURE	1941 (a)(2) STRUCTURE	1941 (a)(3) MINEROLOGY	
1	6-8% L	0-4"	cl	gr	1:1 / fr	1942 WETNES CONDITION - S
		4"-31	c	sbk	1:1 / fi	1943/1956 SAPROLITE - 44" P.S
		31"-44"	c/sap.	sbk/m	1:1 / fi	1944 RESTRICTIVE HORIZON - NA
		44"-48"	sap.	m	fr	1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .3
2	6-8% L	0-5"	cl	gr	1:1 / fr	1942 WETNES CONDITION - S
		5"-30"	c	sbk	1:1 / fi	1943/1956 SAPROLITE - 30" P.S
		30"-41"	c/sap	wsbk/m	1:1 / fr	1944 RESTRICTIVE HORIZON - NA
		41"-48"	sap	m	fr	1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .3
3	6-8% L	0-4"	cl	gr	1:1 / fr	1942 WETNESS CONDITION - S
		4"-24"	c	sbk	1:1 / fi	1943/1956 SAPROLITE - 36" P.S.
		24"-36"	c/sap.	wsbk/m	1:1 / fr	1944 RESTRICTIVE HORIZON - NA
		36"-48"	sap.	m	fr	1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .3
4	6-8% L	0-4"	cl	gr	1:1 / fr	1942 WETNESS CONDITION - S
		4"-23"	c	Abk	1:1 / fi	1943/1956 SAPROLITE - 35" P.S
		23"-35"	c/sap.	Abk/m	1:1 / fr	1944 RESTRICTIVE HORIZON - NA
		35"-48"	sap.	m	fr	1948 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .3
5	6-8% L	0-4"	cl	gr	1:1 / fr	1942 WETNESS CONDITION - S
		4"-24"	c	Abk-wsbk	1:1 / fi	1943/1956 SAPROLITE - 37" P.S
		24"-37"	c/sap.	wsbk/m	1:1 / fr	1944 RESTRICTIVE HORIZON - NA
		37"-48"	sap.	m	fr	1948 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .3

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .3 gpd/ft²
OTHER FACTORS(.1946) SYSTEM TYPE conventional, gravity feed
EVALUATED BY: Mickaff Darwin OTHER(S) PRESENT:
COMMENTS:

DRAFT

00219