HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: A-1 mH OWNER: AGENT: PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____
PROPERTY SIZE: 1 acres
LOCATION OF SITE: lot 3 Happy Lane
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	linear 15%	0 to 4	L	GR		.1942 WETNESS CONDITION	N/A
		4 to 15	C	SBK	1:1	1943/.1956 SAPROLITE	N/A
		15 to 36	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
		36 to 48		Transition		.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	1.35
2	linear 15%	0 to 6	L	GR		.1942 WETNESS CONDITION	N/A
		6 to 18	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		18 to 34	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
		34 to 48		Transition		.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	1.35
3	linear 20%	0 to 8	L	GR		.1942 WETNESS CONDITION	N/A
		8 to 20	C	SBK	1:1	.1943/.1956 SAPROLITE	40"
		20 to 30	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
		30 to 40		Transition		.1948 PROFILE CLASSIFICATION	PS
		40" +		Saprolite		PROFILE LTAR	1.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 1.35
OTHER FACTORS(.1946) _____ SYSTEM TYPE: conv trench
EVALUATED BY: JC Moore OTHER(S) PRESENT: Roger Templeton
COMMENTS: _____

DRAFT