IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 14357B PIN# 4713 71 ~~7550~~ 6489 DATE 8-2-07

OWNER OR APPLICANT Billy Franklin Little JR PHONE: Business 704-880-3068 Home 704-528-1504

ADDRESS 100 Penrith Rd Troutman NC 28166

LOCATION 215 @ Cove @ Pleasant Drive (on) RT LOT # 22/23 CONSTRUED

SUBDIVISION Windsor Est BLOCK / SECTION ____ LOT 22/23 LOT AREA 86450 sqft SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .43

Septic Tank: 1000 Gallons: STB ____ Date ____

Pump Tank: ____ Gallons: PT ____ Date ____

Pump Make: ____ Model ____ Serial No. ____

Nitrification Field: No Fields 1 Square Feet EW=1700 Linear Feet 300'

No Lines 3X100 Trench Width 36" Max Trench Bottom Depth 18" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 6 WITH 25% REDUCTION

Repair System Description: SAME

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Persons 6

☐ Business No. Employees ____

☐ Other ____

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: (1) NOTE MAXIMUM TRENCH BOTTOM DEPTH OF 18" DEEP (2) there is system failure at completely (3) FUTURE LINES ON Contour (MAINTAIN) SERVICE

INITIAL SITE SKETCH

SEE ATTACHED SYSTEM DESIGN BY Lance Cook P.S.

Comments:/Conditions: (4) BUILDER SHOWED LOTS WERE CONSTRUED. PLANS ATTACHED

Red Leaf to Septic Marker

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: ____ date 8-8-07 Installed by: Brent Cochran

Improvement Permit by: ____ date 8-3-07 Operation Permit by: ____ date 3-18-08

Authorization to Construct by: ____ date 8-3-07 Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

PLEASANT DR
1 inch equals 50 feet
100' TO P/L
NEIGHBORS SEPTIC
Patch'd SITE
Proposed
3'x100'
100' REPAIR
House Staked
Lot 23
Drop Boxes
130
131
133
134
307
24
27
326
324
770
10
11
21