Nelson Dellinger Permit #20614Z

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR RICKY DELLINGER DATE 9-7-83 PERMIT NO.

PHONE: Business Home

LOCATION 64-70 west, T.L. at white Oaks on Old Mtn. Rd. - go 1/4 mi. past Trinity Bap. church on left at entrance to Celeste Estates S. R. No.

SUBDIVISION NAME CELESTE ESTATES LOT NO. 15 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Appr. Suitable
Percolation Rate 5 gal/sq ft
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations none observed.

Lot Area Laurel approx
___ Basement with Plumbing ✓ Basement without Plumbing

Existing Bldg: 32 Addition: 42



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Robert Hake

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

Location of the proposed 21'x33' Pole Shed addition does not appear to impact the existing on-site septic system or well.**NOTE:

IMPROVEMENTS PERMIT BY Steve Brown Justin Henderson REHS Date: 10-1-14
ICHD-Environmental Health Division

COMMENTS: Seed grass back over

CERTIFICATE OF COMPLETION BY Steve Brown DATE 9-7-83
EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold