IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR PERRY MILLER DATE 9-5-80 PERMIT NO.

PHONE: Business Home

LOCATION Lfd Hpton Rd. - off I 40 - 1st house on left past Trinity Baptist Church

SUBDIVISION NAME S. R. No.

LOT NO. SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 6 acres

Character & Porosity of Soil clay / fine sandy loam
Percolation Rate .6 gpt / sq ft.
Topography 2-6%
Depth to Water Table 10 +
Rock or other impervious formations NONE



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10" Total.
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY Andrew Causey

COMMENTS:

CERTIFICATE OF COMPLETION BY Steve Brown DATE 9-5-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold