#443

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR MARSH DAGENHART DATE 8-29-83 PERMIT NO.

PHONE: Business Home

LOCATION Old Mtn. Rd. south 2 miles to Henkel School, right 1 mi. T.L. into Celeste Estates - Rt. to last house on Rt. (PORTION OF) S. R. No.

SUBDIVISION NAME CELESTE ESTATES LOT NO. 5 + 6 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Prop. Suitable
Percolation Rate 5 gal/sq.ft.
Topography 2-6% Slope
Depth to Water Table 10'+
Rock or other impervious formations None observed

Lot Area 2.24 acres

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Lineal Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed Connie W. Dagenhart

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Stay out of hill with drainlines. The hill ahead behind the house should be pushed on down. Fill transmitted out to appear there won't be over 6"-12" of fill near drainfield. Keep well at least 50' from S.T. system

CERTIFICATE OF COMPLETION BY DATE

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER
Permit is VOID if any unauthorized changes are made in installation of
Improvements Permit.

The proposed Garage addition does not appear to impact the existing septic system.
**NOTE:

R.S.
Date: 7-2-09
ICHD-Environmental Health Division

JAN. 21, 1989