Sheet 1 of 1

DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #:
COUNTY: Duplin

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Collier Properties APPLICANT: Sim
ADDRESS: Rt 3 Box 366 Kenansville NC APPLICATION DATE: 4-5-99 DATE EVALUATED: 4-19-99
PROPOSED FACILITY: 3 Bd Rm House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ±6.4 ac
LOCATION OF SITE: Lot 43 The Landings Ph 2 Bethlehem Rd (T) Greenwich PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other 2nd Lot on left
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 10%	0-10	SBK C	FI					PS .3
		10-36	SBK C w/ [illegible]	FR					
		36-48	SBK Sa w/C	FR					
2	L 8-10%	0-10	SBK C	FI					PS .3
		10-48	SBK C	FI					
3	L 8-10%	0-10	SBK C	FI					PS .3
		10-36	SBK C	FI					
		36-48+	SBK C w/ [illegible]	FR FI					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200 sq ft Two Fr	35% Reduction
System Type(s)		
Site LTAR	.3	.3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Jeff Lotter
OTHER(S) PRESENT: