IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

James Watt Property

OWNER OR CONTRACTOR Phillip Brooks Trailer DATE 2-12-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 To Rd 1363. T.L. Go Approx 1 Mile. Trailer on L. at Sharp Curve on Road S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	No Perk Test	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Level	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low	
			Rock or other impervious formations	None	

Lot Area Acreage



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 630 Linear Ft. 252

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

House next Door

Installed by Robert Hoke

R. E. Tony

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 2-12-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold