DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Eagle International — APPLICANT: Same
ADDRESS: _____ — APPLICATION DATE: 1-18-01 — DATE EVALUATED: 2/2/01
PROPOSED FACILITY: Bar - 35 Expansion — PROPOSED DESIGN FLOW (.1949): 805 gal — PROPERTY SIZE: _____
LOCATION OF SITE: _____ — PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Linear 7%	0-6	SL fr	VS NP NEP					PS .3
		6-16	SaL fi	SS SP SEP					
		16-29	cL fi	S P SEP					
		29-48	LS Gravel fi	SS SP V					
2	Linear 6%	0-5	SL fi	VS NP NEP					PS .3
		5-14	SCL fi	SS SP SEP					
		14-28	LS Gravel fi	S P V					
		28-34	LCoS fi	SS P V					
		34-48	Sap (LS)						
3	Linear 11%	0-2	SL fr	VS NP NEP					PS .3
		2-12	SCL fi	S P SEP					
		12-36	LS fr	SS P V					
		36-48	LS Sap	fr					
4	Linear	0-8	SL fr	VS NP NEP					PS .35
		8-12	SCL fi	SS SP SEP					
		12-20	SCL fi	SS SP SEP					
		20-26	LS Sap fi	V V V					
		26-36	Sap (LS)						

36-48 Same Sap

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (1945)	PS	PS
System Type(s)	25% Reduction Gravity	25% Reduction Gravity
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: [signature]
OTHER(S) PRESENT: _____