061 71

I

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR DUKE POWER STAMEY TIE STATION DATE 5-21-87 PERMIT NO.

PHONE: Business Home

LOCATION I-40 west-T.R. on old 90 W. of T.R. at Bradford's Rd. - store on right before) west Iredell middle School. S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House ( ) Mobile Home ( ) Business (✓) Other Unmanned station - very limited usage.

No. Bedrooms No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes ( ) No (✓)

Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Sand - suitable.

Percolation Rate 4 gal. / sq. ft.


Topography 2-6%

Depth to Water Table 10'+

Rock or other impervious formations None observed.

Lot Area Acreage

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 1

Sq. Ft. 300 Linear Ft. 100

Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Jones Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Do not park or drive over S.T. system.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 5-21-87

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold