11357.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donald Lackey DATE 4-19-90 PERMIT NO. Pt. of Lot 25

PHONE: Business _____ Home _____

LOCATION Take U.S. 21 to Turnersburg Rd. - T.L. on Watermelon Rd. - go approx. 1/4 mi. on left. Last off rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 Character & Porosity of Soil Clay Subsoil.

Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 60 Min. per Inch


Auto. Dishwasher Yes (✓) No ( ) Topography Slope

Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 12' +

Site Suitable Yes (✓) No ( ) Rock or other impervious formations None Observed.

Lot Area 1.698 acres.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 200 Lines Ft. 300

Depth of Stone in Lines 12

Water Supply: Individual (✓)

Public ( )

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 4-19-90.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold