IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gaither Jenkins Willis Jones Blds DATE 11-26-73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W. To Twp. Gilbert Rd #1512 - T.R. 1st Road T.R. #1616 - Brick House on R

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 1½ Acres.

Character & Porosity of Soil Red Clay
Percolation Rate No Perk Test
Topography Level
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Lackey Bro

IMPROVEMENTS PERMIT BY _____

COMMENTS: House under Construction before Oct 1, 1973

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11-26-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold