Bill Deal Home

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. R. Wooten DATE 4/21/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W. across 3rd Creek. T.R. Ralph Gilbert RD #1513 - Go 9/10 Mile to House on Rt. S. R. No. _____

SUBDIVISION NAME Bill Deal House LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 3 acres


Character & Porosity of Soil Cecil Clay

Percolation Rate _____

Topography Slight Slope Low

Depth to Water Table _____

Rock or other impervious formations None




Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public ( )

Installed by Hoke Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: No Water supply at time of inspection. If well is used it is to be more than 50' from septic tank & lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4/21/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold