IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Freeze DATE 8/10/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64-70 W. T.R. on Jaye Hilbert Rd - T.R. on 1st Paved Rd #1616 (Cook Rd) Go 4/10 Mile - House on Rt. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 150X500

Character & Porosity of Soil Cecil Clay
Percolation Rate _____
Topography 2 - 6% Slope
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY Andrew Causey

COMMENTS: Water from downspouts and all surface water should be diverted away from tank and lines

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 8/10/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold