IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James A. Freeze DATE 4/21/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W. Past 3rd Creek. T.R. on Ralph Gilbert Rd # 1513. Go 8/10 Mile. House on Rt. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 12 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 3 acres


Character & Porosity of Soil Cecil Clay

Percolation Rate _____

Topography Slight Slope

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Hicks Septic Tank.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Divert water from downspouts and surface water away from tank & lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4/29/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold