IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth Dishman Bldr DATE 2-14-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy #90 T.L. on Island Ford Rd. Cross Creek. House on L. Corner Lot at Entrance to Island Ford Park. S. R. No. _____

SUBDIVISION NAME Island Ford Park LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20,000 sq ft

Character & Porosity of Soil Red Clay
Percolation Rate No Perk Test Made
Topography Slope to East
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Harlen Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: House was under Construction Prior to Sept. 1, 1973. Water from Downspouts should be diverted away from septic Tank lines. Important!

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 2-14-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold