IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John George DATE 11/16/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70. Cross 3rd Creek. T.R. into Ashbrook Park on #1616 bear to L. at forks of Rd. T.L. 1st St. House on Rt. S. R. No. _____

SUBDIVISION NAME Ashbrook Park LOT NO. 20 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 20 000 Sq ft


Character & Porosity of Soil Prov. Suitable

Percolation Rate _____

Topography Slope to South Side

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 16"

Water Supply: Individual ( )

Public (✓)

Installed by Eddie Yountz & Son

Washer Drain

Washer Box

Ditch 3X50

16" Stone

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11/20/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold