DEPARTMENT OF ENVIRONMENTAL HEALTH
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Cindy Atkins APPLICANT: ____
ADDRESS: ____ APPLICATION DATE: 7 DATE EVALUATED: 7-11-00
PROPOSED FACILITY: ____ PROPOSED DESIGN FLOW (.1949): ____ PROPERTY SIZE: 3.32 acres
LOCATION OF SITE: Gilbert Rd PROPERTY RECORDED: ____
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	Linear 10%	0 to 48"	C SbK	Fi SEAP	Red	48"	PS	PS	PS .3
2	Linear 10%	0 to 48"	C SbK	Fi SEAP	Redish yellow	48"	PS	PS	PS .3
3	Linear & Gullied		Fillet area unsuitable						
4	None 10%	0 to 48"	C SbK	Fi SEAP	Red	48"	PS	PS	PS .3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv. Gravity	Pump To Conv
Site LTAR	.3	.3

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): PS

EVALUATED BY: J.C. Moore
OTHER(S) PRESENT: Brad & Cindy Atkins