Bobby Combs
Builder

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Denny Lundy DATE 1/3/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy # 90 above Loray - T.L. into Carol Lynn Acres House on Rt. S. R. No. _____

SUBDIVISION NAME Carol-Lynn Acres LOT NO. 52 SECTION OR BLOCK NO. _____


House (+) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (+)
Auto. Dishwasher Yes ( ) No (+)
Auto. Wash. Machine Yes (+) No ( )
Site Suitable Yes (+) No ( )

Lot Area 20,000 Sq ft

Character & Porosity of Soil Prov Suitable
Percolation Rate _____
Topography 2-6% Slope Low
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (+)

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Downspouts and surface water should be diverted away from septic tank & lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 1/3/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold