N.E. Sipet assn Bldrs.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Virgil Hawks DATE 6/2/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy # 90 above Loray. Tr. into Carol Lynn Acres 2nd Lot on Rt past sign S. R. No. _____

SUBDIVISION NAME Carol Lynn Acres LOT NO. 52 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 20,000 Sq Ft


Character & Porosity of Soil Red Clay

Percolation Rate _____

Topography Slight Slope

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Lackey Bros.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Surface Water should be diverted away from Tank & lines

- Lins are Deep Past 1st turn -

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6/2/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold