## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jon Hedrick DATE 9/24-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy # 90 Above Loray - T.R. in Driveway just beyond Adams Septic Tank Co. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | Red Clay |
| Auto. Dishwasher | Yes ( ) | No (✓) | Percolation Rate | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | Slight Slope Low |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | |
| | | | Rock or other impervious formations | None |

Lot Area Acreage




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hardee Lassiter
Adding Bathroom to Existing House

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 9/24/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold