DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: 103832
COUNTY: 4715-20-3579

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: AARON GUY APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: ISLAND FORD W, @ GUY FARM LANE AT END PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1		0-3"	c, med, sbk	f, ss, sp, scxp					PS .35
		3-14"	scp mix c, med, sbk	f, ss, sp, scxp					
		14-48"	loamy scp	f ns np scxp					
2		0-3"	c, med, sbk	f ss sp scxp					PS .35
		3-24"	brownish black loamy scp	f, ss sp scxp					
		24-48"	white loamy scp	f, ss, sp, scxp					
3		0-3"	FILL						PS .3
		3-48"	c, med, sbk	f ss sp scxp					
4		0-48"	FILL						US

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	CONV GRAV	PUMP ATU
Site LTAR	.3	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: B
OTHER(S) PRESENT: _____