IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jarlton-Rinaldo Land Co DATE 4-24-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy #90 Above Loray Tel. into Carol Lynn Acres Bear to R. House on L. S. R. No. _____


SUBDIVISION NAME Carol Lynn Acres LOT NO. 12 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	Satisfactory
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Front
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area 100 X 200



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines Shown on Sketch
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Lackey Bro.

IMPROVEMENTS PERMIT BY William Howard

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4.24.74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold