IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Carlton Rinaldo DATE 6-23-75 PERMIT NO.

PHONE: Business Seth Lumber Co Home

LOCATION Hwy #90 above Lenoir T-L into Carol Lynn Acres 2nd House on L

SUBDIVISION NAME Carol Lynn Acres LOT NO. 49 S. R. No. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 30,000 sq ft


Character & Porosity of Soil Red Clay

Percolation Rate Sub. Dev. Acc

Topography Slope to rear

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Cline Hulleland

IMPROVEMENTS PERMIT BY Andrew Cowan

COMMENTS: Divert Surface water and water from Downspouts Away from Tank & Line

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6.23.75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold