HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 8T-3-A-21
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MELVIN WITMER OWNER: ✓ AGENT: PHONE: (216) 669-3729
ADDRESS: PO. Box 194 APPLICATION DATE: 4/6/94 DATE EVALUATED: 4/11/94
SMITHVILLE, OH 44677 PROPOSED FACILITY: 3BR MH
PROPERTY SIZE: 1.2365 AC.
LOCATION OF SITE: ~~RR~~ # 21 WESTRIDGE
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	H 8%	0-30	C	SBK	1:1 / FR	.1942 WETNES CONDITION	S
		30-36	C/MICA	CR	1:1 / FR	.1943/.1956 SAPROLITE	36+ PS
		36+	SAPROLITE			.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35
2	H 10%	0-28	C	SBK	1:1 / FR	.1942 WETNES CONDITION	S
		28-38	C/MICA	CR	1:1 / FR	.1943/.1956 SAPROLITE	38+ PS
		38+	SAPROLITE			.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	035
3	H 14%	0-24	C	SBK	1:1 / FR	.1942 WETNESS CONDITION	S
		24-38	C/MICA	CR	1:1 / FR	.1943/.1956 SAPROLITE	38+ PS
		38+	SAPROLITE			.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: MELVIN WITMER
COMMENTS:

DRAFT