HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 8T-3-A 32/33
PROPERTY RECORDED:
COUNTY: IRELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MELVIN WITMER OWNER: ✓ AGENT: PHONE: (219) 669-3729
ADDRESS: P.O. BOX 199 APPLICATION DATE: 4/6/94 DATE EVALUATED: 4/7/94
SMITHVILLE, OH 44677 PROPOSED FACILITY: 3BR MH
PROPERTY SIZE: 1.0878 AC
LOCATION OF SITE: LOT # 32/33 WEST RIDGE
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	N 6%	0-28	C	SBK	1:1 / FI	.1942 WETNES CONDITION	S
		28-38	C/MICA	WSBK	1:1 / FR	.1943/.1956 SAPROLITE	PS MIX @ 38
		38-48	C/SAP	WSBK	1:1 / FR	.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33 GPD/FT2
2	L 8%	0-30	C	SBK	1:1 / FI	.1942 WETNES CONDITION	S
		30-40	C/MICA	WSBK	1:1 / FR	.1943/.1956 SAPROLITE	PS MIX @ 40
		40-48	C/SAP	WSBK	1:1 / FR	.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33 GPD/FT2
3	N 14%	0-28	C	SBK	1:1 / FI	.1942 WETNESS CONDITION	S
		28-38	C/MICA	WSBK	1:1 / FR	.1943/.1956 SAPROLITE	PS (MIX @ 38)
		38-48	C/SAP	WSBK	1:1 / FR	.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33 GPD/FT2
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33 GPD/FT2
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: MELVIN WITMER & WIFE
COMMENTS:

DRAFT