HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 8T-3-A-35
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MELVIN WITMER OWNER: ✓ AGENT: PHONE: (216) 667-3729
ADDRESS: PO Box 194 APPLICATION DATE: 4/6/99 DATE EVALUATED: 4/6/99
SMITHVILLE OH PROPOSED FACILITY: 3BR MH
44677 PROPERTY SIZE: 0.56±6 AC
LOCATION OF SITE: WEST RIDGE # 35
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	L 18%	0-10	SC	GR/SBK	1:1 / FR	.1942 WETNES CONDITION	S
		10-40	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE	MIX (a) 40"+
		40-48	C/SAP	CR	1:1 / FR	.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35 GPD/FT²
2	L 8%	0-38	C	SBK	1:1 / FI	.1942 WETNES CONDITION	S
		38-48	C/SAP	GR	1:1 / FR	.1943/.1956 SAPROLITE	MIX (a) 38"+
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35 GPD/FT²
3	L 8%	0-38	C	SBK	1:1 / FI	.1942 WETNESS CONDITION	S
		38-48	C/SAP	GR	1:1 / FR	.1943/.1956 SAPROLITE	MIX (a) 38"+
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35 GPD/FT²
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: MELVIN WITMER & WIFE
COMMENTS:

DRAFT