HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 81-3-A-34
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MELVIN WITMER OWNER: ✓ AGENT: PHONE: (219) 669-3729
ADDRESS: P.O. Box 199 APPLICATION DATE: DATE EVALUATED:
SMITHVILLE, OH 44677 PROPOSED FACILITY: 3BR MH
PROPERTY SIZE: 0.7099 AC
LOCATION OF SITE: LOT # 34 WEST RIDGE
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	L 8%	0-32	C	SBK	1:1 / FI	.1942 WETNES CONDITION S
		32-48	C/MICA	WSBK	1:1 / FR	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.33 GPD/FT2
2	L 10%	0-34	C	SBK	1:1 / FI	.1942 WETNES CONDITION S
		34-48	C/MICA	W/SBK	1:1 / FR	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.33 GPD/FT2
3	L 18%	0-28	C	SBK	1:1 / FI	.1942 WETNESS CONDITION S
		28-38	C/MICA	W/SBK	1:1 / FR	.1943/.1956 SAPROLITE PS - MLX - (D) 38
		38-48	C/SAP	WSBK	1:1 / FR	.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.33 GPD/FT2
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33 GPD/FT2
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONVENTIONAL GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: MELVIN WITMER & WIFE
COMMENTS:

DRAFT