HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 8T-3-A-28
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MELVIN WITMER OWNER: AGENT: PHONE: (26) 669-3739
ADDRESS: P.O. Box 194 APPLICATION DATE: 4/6/99 DATE EVALUATED: 4/11/99
SMITHVILLE, OH 44677 PROPOSED FACILITY: 3BR MH
PROPERTY SIZE: 0.7676 AC
LOCATION OF SITE: #28 / WEST RIDGE
WATER SUPPLY: On-Site Well / Comm. Well Public Other EVAL. METHOD: Auger Boring / Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 25%	0-30	C	SBK	1:1 / FI	.1942 WETNES CONDITION: S
		30-38	C/MICA	WSBK	1:1 / FR	.1943/.1956 SAPROLITE: 38"+
		38+	SAPROLITE			.1944 RESTRICTIVE HORIZON: S
						.1948 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.33 GPD/FT2
2	L 25%	0-32	C	SBK	1:1 / FI	.1942 WETNES CONDITION: S
		32-39	C/MICA	CR	1:1 / FR	.1943/.1956 SAPROLITE: 39"+
		39-48	SAPROLITE			.1944 RESTRICTIVE HORIZON: S
						.1948 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.33 GPD/FT2
3						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1945 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -
4						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -
5						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -

AVAILABLE SPACE (.1945): S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33 GPD/FT2
OTHER FACTORS(.1946): NONE SYSTEM TYPE: CONV. GRAVITY / CONV. & LPP REPAIR
EVALUATED BY: S. HODRICK OTHER(S) PRESENT: MELVIN WITMER & WIFE
COMMENTS:

DRAFT