IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William Ambert DATE 26 Sept 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 90 to Rt 15 1/2 just before Cross Creek School on left to creek bridge to top of hill. Lot on Right S. P. N. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms Bedroom 3 No. Baths 2 Character & Probable Soil Red Clay Loam


Sewage Disposal Co.: Yes ( ) No (✓) Percolation Rate _____

Auto. Dishwasher: Yes ( ) No (✓) Topography Slope to front of lot

Auto. Wash. Machine: Yes (✓) No ( ) Depth to Water Table 2'

Site Suitable: Yes (✓) No ( ) Rock or other adverse conditions Rock and Boulders

Lot Area Adequate



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 24"

Water Supply: Individual (✓)
Public ( )

Installed by Tinsley Bros

Sq ft 625

Lin ft 250

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Ralph Tyson DATE 26 Sept 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

JAN. 8, 1989 20:34