IREDELL COUNTY HEALTH DEPARTMENT
IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

STATESVILLE 704-878-5305 (cal) MOORESVILLE 704-664-5281

DATE 31 July 08

PERMIT# 150613 PIN# 4715-54-6120 PHONE: Business 704-872-7855 Home 704-902-8735

OWNER OR APPLICANT C&D Excavating

ADDRESS 118 Sams Trail Lane, Statesville, N.C.

LOCATION Nov 64 - Turn onto Woodbridge - TL Russell Rider TR Drop Lot on Rt.

SUBDIVISION Woodbridge Estates BLOCK / SECTION 2 LOT 19 LOT AREA 0.746 Ac. SITE CLASS PS DESIGN FLOW 480 gpd L.T.A.R. 0.5 gal/ft²/d

Septic Tank: 1000 Gallons: STB 325-1000 Date 7-06-14

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet ≈ 1600 Linear Feet 400

No Lines 3 Trench Width 36" Max Trench Bottom Depth 36 Gravel Depth

☑ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 25% Reduction

Repair System Description: 50% Reduction

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☐ Individual ☑ Public ☐ Community

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing ☑ Gravity ☐ Pressure

Comments/Conditions: Follow contour / Keep 15' from DWIC of Gully / Meet setback requirements.

Comments/Conditions:

INITIAL SITE SKETCH

Please see Attached Layout

AS BUILT SKETCH

- Installed as drawn
- Quick 4 Chambers installed
- Blue Filter installed
- Tuff-Tank 1500 gal installed

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

☐ Permit with plat valid without expiration ☑ Improvement Permit with site plan valid for sixty months

Signed: date 5-15-08 Installed by: Rowan Septic date 10-28-14

Improvement Permit by: J. Hoyle, R.S. date 31 July 08 Operation Permit by: Justin Mendez date

Existing System Inspection by: J. Hoyle, R.S. date 31 July 08

OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

HEALTH DEPT. COPY: WHITE