IREDELL COUNTY HEALTH DEPARTMENT

Bldr. A. Robertson

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William Summers DATE 1 Feb 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 90 to Looney. Shopping Center on Left. House on Right across Railroad. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No (●)	
Auto. Dishwasher	Yes (✓)	No (●)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Red Clay - Tight


Percolation Rate None

Topography Slope to Rear

Depth to Water Table unk

Rock or other impervious formations unk

Lot Area _____



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 644 Linear Ft. 276
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public ( )

Installed by Harlan Farley

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY William M. Howard DATE 1 Feb 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold