IREDELL COUNTY HEALTH DEPARTMENT
Phone 1164

County Building — Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. 639 — Permit Date 6-2-48 194___

Owner Concord Lbr. Mfg. Co. — Address Loray, N.C.

Tenant " " — Address "

Installed by G.F. Barnes-Lumber Co. — Address Loray, N.C.

Location of property Loray, N.C.

Kind of tank Concrete BK Capacity 600 Length of trench 210


NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection 6-2-48 194___ Approved (✓) Disapproved ( )

Remarks: OK

First five feet of line from outlet should be of cast iron soil pipe.



J E Verble
Sanitarian.

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.