Dave Prichard Builder

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jommy Cook DATE 3-13-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy # 90 to Rd # 1512 Near Loray - House on R. Abbrox ¼ Mile S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 2 9cres


Character & Porosity of Soil Red Clay

Percolation Rate No Perk Test

Topography Slope to Back Low

Depth to Water Table None Noted

Rock or other impervious formations



Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 630 Linear Ft. 252

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Lackey Bro.

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Down spouts from house and all surface water Possible should be diverted away from system.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 3-13-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold