DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ~~Joe Tenant~~ David Marter APPLICANT: ~~Joe Tenant~~ David Marter
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 2/14+17
PROPOSED FACILITY: 2BR w/conv PROPOSED DESIGN FLOW (.1949): 240 PROPERTY SIZE: 15,000' +/-
LOCATION OF SITE: _____ PROPERTY RECORDED: Yes
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	6% Linear	0-16	c ABk	Fi S P SE+p					PS .25
		16-33	c/cl SBk	FrAf SS SP SE+p					
		33-43	cl w/Sap Fm	Fr SS SP SE+p					
		43-48	Sap (c)	NS NP					
2	5% Linear	0-6	c ABk	F S P SE+p					PS .3
		6-16	cl SBk Fm	Fr/fi SS SP SE+p					
		16-33	cl w/Sap Fm	Fr SS SP SE+p					
		33-48	Sap m (c)	FrVS NP NK+p					
3									
4									

DESCRIPTION	INITIAL SYSTEM	~~REPAIR SYSTEM~~
Available Space (.1945)	PS	NA
System Type(s)	gravity Parcel 6	
Site LTAR	.25	

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____