IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Brothers Realty DATE 1-14-81 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 90 to Jersey - Turn (R) on S.R. 1548 before church, go ¼ mile on left. S. R. No. _____

SUBDIVISION NAME Concordia Dev. LOT NO. #1 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 1.5

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil cecil clay
Percolation Rate 45 gal/sq. ft.
Topography 6-15% ✓
Depth to Water Table 10'+
Rock or other impervious formations none observed.

Lot Area 20,000 sq. ft.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1200 Linear Ft. 133
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bros.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: The septic tank for this installation must have a baffle wall in order to be approved.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 1-14-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold