07758

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR THOMAS PEOPLES DATE 1-29-98 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Hwy 90W to S.R. on Little Fork Rd. - ½ mi on left - enter 1st st. on right on left. S. R. No. _____

SUBDIVISION NAME CEDAR RIDGE DEV. LOT NO. 7 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 Character & Porosity of Soil Prev. Suitable.
Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 5 Min. /Sq. Ft.
Auto. Dishwasher Yes ( ) No (✓) Topography 2-6%
Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 10'+
Site Suitable Yes (✓) No ( ) Rock or other impervious formations None Observed.
Lot Area ½ acre+

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Dennis Gallider

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 1-29-98

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold