07984

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Lackey DATE 3/28/88 PERMIT NO.

PHONE: Business Home

LOCATION 90W, Rt on Little Farm, Lot on Lf at 1st Entrance

S. R. No.

SUBDIVISION NAME Cedar Ridge LOT NO. 6 SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other Doublewide


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Fair Suitable
Percolation Rate 2-64
Topography 2-67
Depth to Water Table
Rock or other impervious formations None Noted

Lot Area

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 24"

Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Stan Brown

COMMENTS: Keep lines wholly separated from each other to prevent seepage between the lines.

CERTIFICATE OF COMPLETION BY [signature] DATE 3/28/88

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold