DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Property Rights APPLICATION DATE _____
ADDRESS: _____
PROPOSED FACILITY: 3bdrm PROPOSED DESIGN FLOW (.1949): 360 GPD DATE EVALUATED: 29 Oct 09
LOCATION OF SITE: Carrington Rd PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	P <3%	0-14	SLK/SCL	vFI/sof	>48	>48	—	—	P 0.7
		14-48+	SLK/SC	FI/sof					
2	P <3%	0-18	SLK/SCL	FI/sof	>48	>48	—	—	P 0.7
		18-48+	SLK/SC	FI/sof					
3	P <3%	0-14	MSKL/SCL	vFI/sof	>48	>48	—	—	P 0.7
		14-48+	SLK/SC	FI/sof					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	30	30
System Type(s)	36% Red	36% Red
Site LTAR	0.7	0.7

OTHER FACTORS (.1946): P
SITE CLASSIFICATION (.1948): P
EVALUATED BY: [illegible]
OTHER(S) PRESENT: _____

COMMENTS: _____