[R]DELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 2411b DATE 8-16-96 TAX MAP NO. 9D-A-47 Pt of6 Watershed: ☐ Yes ☐ No

OWNER OR CONTRACTOR C, P Inc of Florence PHONE: Business 910 686 7084 Home

ADDRESS 632 Bayshore wilmington 28405

LOCATION 90w on Rt before boray back across RR Tracks

SUBDIVISION BLOCK / SECTION LOT LOT AREA 11acres SITE CLASS. PS DESIGN FLOW 1750 L.T.A.R. .13

Septic Tank: 2000 Gallons; STB 633 Date 2-5-96
Pump Tank: 2500 Gallons; PT 96 Date 7-23-96
Pump Make: Hydromatic Model 1 Horsepower Serial# 100
Nitrification Field: No Fields 1 Square Feet 2500 Linear Feet 833.3
No Lines 8 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth 12"

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI
System Description: Pump To conv. lines
Repair System Description: " " " "
Maintenance Agreement Required: ☐ Yes ☑ No
☑ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

☐ House/Mod. Home No. Bedrooms
☐ Mobile Home No. Bathrooms
☑ Business No. Employees 30
☐ Other Frozen Fut Storage Warehouse

Water Supply:
☐ Individual
☐ Community
☑ Public

Comments:

Pump Tank

Comments:

Area over Septic Tank & Pump Tank will be restricted from Vehicular Traffic

INITIAL SITE SKETCH

See Attached Plan by B.K Barringer Inc which is Part of This Permit. Date may 31, 1996 R.J. Pennington Inc.

AS BUILT SKETCH

area over drain lines must be sowed with Grass & keep mowed System Installed according to approved Plans

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system.

Signed:

Installed by: Dale FOX

Improvement Permit by: P.C. Moore date 8-16-96

Authorization to Construct by: P.C. Moore date 8-16-96

Certificate of Completion by: date

Operation Permit by: P.C. Moore date 5-23-97

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD

to const. authorization to const. Expires 60 mos from issue

912000