IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ray Franklin DATE 12-14-72 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 90 - To Rd # 1551 (Scotts Rd) T.R. - Go .08 mile. Brick House on L. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area 4 Acres

Character & Porosity of Soil Red Clay
Percolation Rate Mc Kee Test
Topography Sloping to back
Depth to Water Table 5 Feet
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Harlan Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: House under Construction Prior to Oct. 1, 1973

CERTIFICATE OF COMPLETION BY E G Stutesman DATE 12-14-72

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold