DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet
PROPERTY ID #
COUN

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Roger Maggiotto APPLICANT: Same
ADDRESS: [illegible] Lake Dr. APPLICATION DATE: 5/14/01 DATE EVALUATED: 6/19/01
PROPOSED FACILITY: 3BR House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ~.5 Ac
LOCATION OF SITE: Cul de Sac PROPERTY RECORDED: ?
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	6% Linear	0-8	SCR	Fr NSVP/NE					PS .35
		8-18	2/co Smic. MBK	Fr SS SP SE/P					
		18-26	2f 4/Sap Fmic	Fr SBK/Fi SS SP SE/P					
		26-48	Sap 4/1 CR Fmic MSBK	Fr NE/EP					
2	7% Linear	0-7	SCR	Fr SS P					PS .35
		7-16	2f/c Fmic SBK	Fi/Fr SS SP					
		16-48	2f Fmic SBK	Fr NS P					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity 250 Lin Ft	Pump 250 Lin Ft
Site LTAR	.35	.35

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: