DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____


SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Tim Stikeleather APPLICANT: Tim Stikeleather
ADDRESS: Township Hwy APPLICATION DATE: 3-20-04 DATE EVALUATED: 5/5/04
PROPOSED FACILITY: 3Bdrm Home PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .76 Acre
LOCATION OF SITE: _____ PROPERTY RECORDED: Yes
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Jo-Monni Acres #85-91

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	6% Linear	0-9	scl sbk	vfr ss np se/p					PS .30
		9-38	c sbk	fr ss sp se/p					
		38-48	cl/sicl sbk	fr ss sp se/p					
2	7% Linear	0-5	scl usbk	vfr ss np se/p					PS .30
		5-38	c sbk	fr ss sp se/p					
		38-44	c w/org sbk	fr ss sp se/p					
		44-49	sap						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Ground Abs. w/ Reduction	Pump 50% Reduction
Site LTAR	.30	.30

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: B. K Johnson
OTHER(S) PRESENT: _____


House Site
Drive
Jonum Loop