Bobby Comes, Bldr.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Roy R. D. Morgan DATE 2-17-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jo Moni Acres

S. R. No. 1653

SUBDIVISION NAME Jo Moni Acres LOT NO 1-2-3-4 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 20,000 sq ft+


Character & Porosity of Soil Red Clay

Percolation Rate _____

Topography Slope to E. Side

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 750 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: Surface water and downspouts from house should be diverted away from Tank + Lines. Extra dirt to be filled in at second turn.

CERTIFICATE OF COMPLETION BY E. C. Stevenson DATE 2-17-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold