DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Clyde Harman APPLICANT: _____
ADDRESS: 2811 Meadowbrook Rd APPLICATION DATE: 5 6 99 DATE EVALUATED: 5.19.99
PROPOSED FACILITY: 3 bdrm hm PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ~50 Ac
LOCATION OF SITE: 1151 Scotts Creek on Left ~2 x 3 miles PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 2%	0-18	Plow						PS .3
		18-36	SBK C	FI SS SP SEHP					
		36-48	SBK C	FI					
2	L 2%	0-18	Plow						
		18-36	SBK C	FI SS SP SEHP					
		36-48	SBK C	FI SS SP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	120	100
System Type(s)	Conventional	20-50% Red.
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [illegible]
OTHER(S) PRESENT: [illegible]