04362

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR FOY MARLOWE DATE 3-25-86 PERMIT NO.

PHONE: Business Home

LOCATION Hwy 115 N - T.L. on Sullivan Farm Rd. - cross over old 115 + go approx. 2.5 miles to T.R. on st. just past Betsy grocery house - 1/4 mi. on left S. R. No.


SUBDIVISION NAME LOT NO. 13 PT. 1&2 SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1-2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 100' x 200'

Character & Porosity of Soil Prop. Suitable.
Percolation Rate 1 Spl/sq. ft.
Topography 6-10% fall
Depth to Water Table 10'+
Rock or other impervious formations none observed.



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Kenneth Chaffin

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS:

CERTIFICATE OF COMPLETION BY Steve Brown DATE 3-25-86.

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold