04361

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Foy Marlowe DATE 3-25-86. PERMIT NO.


PHONE: Business Home

LOCATION Hwy 115 N - T. L. on Sullivan Farm Rd - cross over old 115 onto Scotts Creek Rd - go approx. 2.5 miles on (-) - enter st. - down hill on (-). S. R. No.

SUBDIVISION NAME LOT NO. 22 SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2-3 No. Bathrooms 1-2 Character & Porosity of Soil Prev. Suitable.
Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate Sat. / 5 min. / 1 ft.
Auto. Dishwasher Yes ( ) No (✓) Topography 2-6%
Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 10'+
Site Suitable Yes (✓) No ( ) Rock or other impervious formations none observed.
Lot Area 100' x 200'



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Kenneth Chaffin

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS:

CERTIFICATE OF COMPLETION BY Steve Brown DATE 3-25-86.

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold