04430

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR FOY MARLOWE

PHONE: Business _____ Home _____ DATE 4-17-86. PERMIT NO. _____

LOCATION Hwy 115 N - T.L. on Scotts Creek Rd. - go 2 3/4 mi. enter dev. on (C) - lst rear end on (C).


SUBDIVISION NAME FOY MARLOWE PROPERTY LOT NO. 17 S. R. No. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2-3 No. Bathrooms 1-2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Poor Suitable.
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate 5 gal/sq. ft.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 18"+
Lot Area Ample			Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Kenneth Claffin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 4-17-86.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold