04362

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Foy MARLOWE DATE 3-20-86 PERMIT NO.

PHONE: Business Home

LOCATION Hwy 115 N - T.L. on Sullivan Farm Rd. - cross over old 115 + go 2.5 miles - T.R. onto dirt st. near end on (R).

SUBDIVISION NAME S. R. No.


LOT NO. 16 SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2-3 No. Bathrooms 1-2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Sandy Suitable
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate Equal to 5 min/ft.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 12'+
Lot Area 100' x 200'			Rock or other impervious formations none observed.

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Foy Marlowe

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Tank + lines to be installed at proper depth. Clear enough trees for installation.

CERTIFICATE OF COMPLETION BY

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold